



Kingsman Academy PCS - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Kingsman Academy PCS	WS-078-003	Bottle Filler	1	In hallway adjacent to staff restroom			WF-012025-078003-05	6/19/2025	FT-FY25-012025-078003-A	<1	FT-FY25-012025-078003-B	<1
Kingsman Academy PCS	WS-078-005	Bottle Filler	1	In hallway adjacent to boys' and girls' restrooms			WF-012025-078005-07	6/19/2025	FT-FY25-012025-078005-A	<1	FT-FY25-012025-078005-B	<1
Kingsman Academy PCS	WS-078-007	Bottle Filler	1	In hallway adjacent to 109			WF-012025-078007-07	6/19/2025	FT-FY25-012025-078007-A	<1	FT-FY25-012025-078007-B	<1
Kingsman Academy PCS	WS-078-009	Bottle Filler	2	In hallway adjacent to 207			WF-012025-078009-07	6/19/2025	FT-FY25-012025-078009-A	<1	FT-FY25-012025-078009-B	<1
Kingsman Academy PCS	WS-078-012	Bottle Filler	2	In hallway adjacent to 209			WF-012025-078012-07	6/19/2025	FT-FY25-012025-078012-A	<1	FT-FY25-012025-078012-B	<1
Kingsman Academy PCS	WS-078-015	Bottle Filler	3	In hallway adjacent to 306			WF-012025-078015-07	6/19/2025	FT-FY25-012025-078015-A	<1	FT-FY25-012025-078015-B	<1
Kingsman Academy PCS	WS-078-017	Bottle Filler	3	In hallway adjacent to restroom			WF-012025-078017-07	6/19/2025	FT-FY25-012025-078017-A	<1	FT-FY25-012025-078017-B	<1