



Kingsman Academy PCS - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Kingsman Academy PCS	WS-078-005	Cooler	1	In hallway adjacent to boys' and girls' restrooms	High	Right	WF-022021-078005-03	5/19/2021	FT-FY21-022021-078005-A	<1	FT-FY21-022021-078005-B	<1
Kingsman Academy PCS	WS-078-006	Cooler	1	In hallway adjacent to boys' and girls' restrooms	Low	Left	WF-022021-078006-03	5/19/2021	FT-FY21-022021-078006-A	<1	FT-FY21-022021-078006-B	<1
Kingsman Academy PCS	WS-078-007	Cooler	1	In hallway adjacent to 109	High	Right	WF-022021-078007-03	5/19/2021	FT-FY21-022021-078007-A	<1	FT-FY21-022021-078007-B	<1
Kingsman Academy PCS	WS-078-008	Cooler	1	In hallway adjacent to 109	Low	Left	WF-022021-078008-03	5/19/2021	FT-FY21-022021-078008-A	<1	FT-FY21-022021-078008-B	<1
Kingsman Academy PCS	WS-078-009	Cooler	2	In hallway adjacent to 207	High	Left	WF-022021-078009-03	5/19/2021	FT-FY21-022021-078009-A	<1	FT-FY21-022021-078009-B	<1
Kingsman Academy PCS	WS-078-010	Cooler	2	In hallway adjacent to 207	Low	Right	WF-022021-078010-03	5/19/2021	FT-FY21-022021-078010-A	<1	FT-FY21-022021-078010-B	<1
Kingsman Academy PCS	WS-078-011	Break Room	2	In teachers' lounge 208			WF-022021-078011-03	5/19/2021	FT-FY21-022021-078011-A	<1	FT-FY21-022021-078011-B	<1
Kingsman Academy PCS	WS-078-012	Cooler	2	In hallway adjacent to 209	High	Left	WF-022021-078012-03	5/19/2021	FT-FY21-022021-078012-A	<1	FT-FY21-022021-078012-B	<1
Kingsman Academy PCS	WS-078-013	Cooler	2	In hallway adjacent to 209	High	Right	WF-022021-078013-03	N/A	FT-FY21-022021-078013-A	Non-Op	FT-FY21-022021-078013-B	Non-Op
Kingsman Academy PCS	WS-078-015	Cooler	3	In hallway adjacent to 306	High	Right	WF-022021-078015-03	5/19/2021	FT-FY21-022021-078015-A	<1	FT-FY21-022021-078015-B	<1
Kingsman Academy PCS	WS-078-016	Cooler	3	In hallway adjacent to 306	Low	Left	WF-022021-078016-03	N/A	FT-FY21-022021-078016-A	Non-Op	FT-FY21-022021-078016-B	Non-Op
Kingsman Academy PCS	WS-078-017	Cooler	3	In hallway adjacent to restroom			WF-022021-078017-03	5/19/2021	FT-FY21-022021-078017-A	<1	FT-FY21-022021-078017-B	<1